

MODULE B: EU TYPE-EXAMINATION – PRODUCTION TYPE

Issued by DBI Certification, notified body No. 2531

The equipment identified below which was found to be in compliance with the essential requirements of the Regulation of Appliance burning gaseous fuels (EU) 2016/426 Annex III, 1, subject to any conditions in the description attached hereto.

Manufacturer Integrated Gas Technologies Aps
Address Gydevang 39-41, DK-3450 Allerød, Denmark
Type of Appliance Regulator
Trade Mark IGT
Type/Model B300 and B310
Specified Standards EN 16129:2013


**The attached (*description of type approval*) forms part of this certificate.
This certificate remains valid unless suspended or withdrawn, provided the conditions in the attached description are complied with and the equipment remains satisfactory in service.**


Valid from 2018-04-21 Issued by DBI Certification Notified Body No. **2531**

Expiry date 2028-04-21

Signed

Name


Ken T. Olesen
Responsible for evaluation


Merete Poulsen
Responsible for certification decision

Note:

This certificate will not be valid if the manufacturer makes any changes or modifications to the approved equipment, which have not been notified to, and agreed with the notified body named on this certificate.

(Annex)
Description of Type

Product Description

Trade Marks IGT
Type/Model B300 and B310

Country of destination	Category	Pressure
All EU	I _{3B/P}	1.5 bar
All EU	I _{3B/P}	2.0 bar
All EU	I _{3B/P}	2.5 bar
All EU	I _{3B/P}	4.0 bar

Technical Data

Gas type: LPG
Inlet pressure: 1.5 bar – 16 bar
Capacity: 8.0 kg/h
Temperature: -20°C - +50°C

Inlet connection: Male (B300) Female (B310)
G7, G9, G10 G1, G2, G4, G5, G8, G11, G12

Outlet connection: H1, H4, H5, H6, H50, H51 H1, H4, H5, H6, H50, H51

Comments -

Technical Documentation

Test report: SGS test report no. SDHL1711024312GA dated 2018-01-09, regarding compliance with:
- Regulation of Appliance burning gaseous fuels (EU) 2016/426
- EN 16129:2013

Statements: Declaration of Conformity from the manufacturer dated 2017-12-04
Risk Management Report from the manufacturer dated 2017-11-28

End of Certificate